

**DESCRIPTION**


Project Name:	Metro L6
Section Name:	Viga eje 1
Sensor Name:	Sensor 1 SM2
Location:	
Tagged By:	-
Pouring Time:	05/08/2017 11:51 a.m.
Mix ID:	Demo mix 2
Maturity Method:	Temperature Time Factor
Datum Temperature:	0.0°C
Calibration coefficient:	a= 1,00      b= 9,70
Comments:	-




**TEST RESULTS**

Max Temperature:	90,0 °C
Min Temperature:	3,0 °C
Maturity Index:	256 °C-hrs
Strength:	24,4 MPa


**TEMPERATURE**



**MATURITY**



**STRENGTH**



signature